

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3515-0713:103 Page 1 of 1

CATEGORY: Rolling Steel Door (Fire-Rated)

LISTEE: Cookson, 2417 S. 50th Ave., Phoenix AZ 85043
Contact: *Richard Cookson (602) 272-4244

DESIGN: 22 gauge galvanized or stainless steel slats, bottom bar, wall guides, hoods, barrel assembly automatic release device, governor and counter balance mechanism.
Doors may be manual or provided with motor drive assembly which does not interfere with the manual or automatic (fusible link) closing of the door. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: UL, FM or Warnock Hersey label.

APPROVAL: Listed as 3-hour, 12-hour or 3/4-hour fire-rated doors for use in concrete and masonry walls.
Rolling steel fire doors maximum size of openings:

WH Label	8'W x 10'H	Maximum 80 sq. ft.
UL, FM Label	13'6"W x 13'6"H	Maximum 152 sq. ft.

For doors exceeding 13'6" in any dimension and 152 sq. ft in area are considered oversize doors and are not cover under this listing. The design of these doors is based upon, and is similar to, the approval product design but they have not been subject to approval testing due to test facility limitations. Acceptance of these doors is the prerogative of the authority having jurisdiction.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager